



# Product Evaluation

DR806 | 1216

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** DR-806

**Effective Date:** December 1, 2016

**Re-evaluation Date:** November 2020

**Product Name:** 8'-0" Craftsman Series Fiberglass Glazed Entry Single Side-Hinged Doors, Inswing/Outswing, with and without Sidelites, Non-Impact Resistant

**Manufacturer:** Plastpro, Inc.  
5200 W. Century Blvd.  
Los Angeles, CA 90045  
(440)969-9773

## General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 8'-0" Glazed Fiberglass Single Door, Inswing / Outswing; (X)	Inswing +35/-50 psf Outswing +40/-40 psf	TX-4611
2	3'-0" x 8'-0" Glazed Fiberglass Single Door, w/Sidelite & Integral Mullion Inswing / Outswing; (OX/XO)	Inswing +35/-50 psf Outswing +40/-40 psf	TX-4611
3	3'-0" x 8'-0" Glazed Fiberglass Single Door, w/Sidelite & Integral Mullion Inswing / Outswing; (OXO)	Inswing +35/-50 psf Outswing +40/-40 psf	TX-4611

## Component Dimensions:

System	Overall Size	Panel Size		Daylight Opening Size	
		Door	Sidelite	Door	Sidelite
1	37.50" x 98"	35.75" x 95.43"	N/A	24.75" x 22"	N/A
2	53" x 98"	35.75" x 95.43"	13.87" x 95.25"	24.75" x 22"	7.50" x 21.75"
3	68.50" x 98"	35.75" x 95.43"	13.87" x 95.25"	24.75" x 22"	7.50" x 21.75"

**Components and Hardware:**

System	Component	Quantity	Attachment Method
1,2,3	4" Butt Hinges	4	Hardware and components must be installed in accordance with Plastrpro drawing TX-4611 dated April 26, 2016, signed and sealed by Lyndon F. Schmidt, P.E. on 4-26-2016.
	Kwikset Series (400) Knob Kwikset Series (660) Deadbolt Or Schlage F-Series Knob Schlage B-Series Deadbolt Or Yale Knob (100 C) & Deadbolt (820)	1 each	

**Product Identification (Manufacturer Label on Door):**

System		
1,2,3	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Plastrpro, Inc.
	Product Name	3'0" x 8'-0" Glazed Fiberglass Single Doors w/ and w/out Sidelites, Inswing/Outswing
	Drawing	TX-4611
	Test Standards	ASTM E330-02

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris.

**Acceptance of Smaller Assemblies:** Door assemblies with dimensions equal to, or smaller than those specified are acceptable with the limitations specified in this report.

**Sidelites:** Sidelites must only be used with door. Sidelites must not be installed individually.

**Installation:**

System		
1	Type of Installation	Doors must be installed in accordance with Plastrpro drawing TX-4611 dated April 26, 2016, signed and sealed by Lyndon F. Schmidt, P.E. on 4-26-2016.
	Wall Framing	
	Fasteners	
	Fastener Embedment	
	Fastener Location/Spacing	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.